

FURNISHINGS

This section of the Washington University School of Medicine (WUSM) Design Standards addresses the following requirements for Furnishings and its application in WUSM projects:

WINDOW TREATMENTS

WINDOW TREATMENTS

DESIGN GUIDELINES

1. Exterior windows shall receive window treatments. Window blinds are standard in all locations.
2. Window shades may be appropriate in some locations as reviewed and approved by WUSM Capital Projects. Both exposure and function shall be considered in determining appropriate openness of shade type for each opening. Samples of all shade materials shall be submitted for review and approval.

PRODUCT REQUIREMENTS

1. Blinds shall be horizontal miniblinds with 1-inch aluminum louver slats.
2. Roller window shades shall be manually operated. Motor operated shades shall be by exception only.

INSTALLATION

1. Window treatments shall be installed level and plumb and aligned with adjacent units.
2. Window treatments shall be installed within opening.