

WUSM BUILDINGS

Quick Contractor / Project Safety Check List

PM's will review each of these points that pertain to their project and have the general contractor sign this form after the pre-construction meeting signifying he / she understands our intent for a safe project.

Safety is the number "1" priority at WUSM

- 2-Help (362-4357) Fire / Ambulance / Spill / Security
- Maintenance 362-3100 or 362-3102 (24 hr. computer room)
- Contractor emergency contact list
- Hot work permit & on site instructions
- Fire Extinguishers at exits
- Safety Data Sheets for all (paints, glues, solvents etc.)
- PPE (especially hard hats & Glasses)
- Utility outage procedures, normally two week notification
- Fall protection / Safety harness (both personnel and equipment / tool tie down)
- Job site housekeeping / regular trash removal/ regular elevator door track cleaning / no tobacco and shell spitting etc.
- Confined space / air monitoring / tripod use / buddy system
- No smoking, spitting in/on Med School buildings & parking lots
- Fluorescent lamps, ballast and hazard waste disposal
- Smoke detectors, Sprinkler, Standpipe Procedures
- WUSM Infection Control Risk Assessment Form and procedures/notification of mold, lead and asbestos findings
- Coordination between contractors Lock-out-tag-out and WUSM
- Railings/Kick boards/Scaffoldings/ Ladders
- Trenching / Set backs / Shoring / Soil classification / Daily soil evaluation
- Rigging Procedures
- Fencing & Signage
- Temporary exiting strategies & signage
- Road guards / safety vest / traffic signage
- Written safety procedures on specific jobs (hoisting, helicopter, etc.)
- HEPA filtration on site / number depends on situation & size

Project #'s _____ **Name** _____ **Date** _____

General Contractor Signature _____ **WUSM** _____